

**CLIENT: REWOOD, LLC**  
13574 Martinique Drive  
Chino Hills, CA 91709  
Zoraida Morales

**Test Report No: RJ1192-1**

**Date: February 14 2011**

**SAMPLE ID:** The test samples are identified as specimens of Resysta Decking.

**SAMPLING DETAIL:** Test samples were submitted to the laboratory directly by the client. No special sampling conditions or sample preparation were observed by QAI.

**DATE OF RECEIPT:** Samples were received at QAI on February 10, 2011.

**TESTING PERIOD:** February 14, 2011.

**AUTHORIZATION:** Testing authorized by Zoraida Morales.

**TEST REQUESTED:** Perform standard flame spread and smoke density developed classification tests on the sample supplied by the Client in accordance with ASTM Designation E84-09, "Standard Method of Test for Surface Burning Characteristics of Building Materials". The foregoing test procedure is comparable to UL 723, ANSI/NFPA No. 255, and UBC No. 8-1.

<b>TEST RESULTS:</b>	<b><u>Flame Spread</u></b>	<b><u>Smoke Developed</u></b>
	25	450

Detailed test results are presented in the subsequent pages of this report

**CONCLUSION:** The submitted material meets the requirements for a "Class A" Flame Spread. See classification requirements on page 2.

**Prepared By**

  
Brian Ortega  
Test Technician

**Signed for and on behalf of  
QAI Laboratories, Inc.**

  
Greg Bahasky  
Senior Test Technician

Page 1 of 3  
THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED.