



PORT DE LA MER

PLOT NO. PDLM 03, JUMEIRAH FIRST, DUBAI, UAE



Sustainability (DGBR) Compliance Form

Material Submittal Number:	PDLM-MW-TPL-MT-AR-00339
Product Name:	Composite Timber Cladding Works
Material Manufacturer:	Treepal Resysta Middle East
Location of Use:	All Buildings, where applicable (Pergolas and windows/ doors shutters)
Material Submittal Rev #:	0

This is to confirm that Climatize has reviewed the indicated material submittal and have found the material:

- A- Approved**, no further DGBR documentation required
- B- Approved as noted**, further DGBR documentation required to be submitted within 1 month or otherwise stated: _____
- C- Revise and Resubmit**, further DGBR documentation required to demonstrate compliance
- D- Rejected**, Non-compliant DGBR material
- E- Not Applicable**, Non-applicable DGBR material

Applicable DGBR Clause # and Title	Compliance Statement/ Remarks
304.01 Urban Heat Island Effect	SRI test report from DCL provided. Minimum SRI of 29 is achieved.
701.02 Certified Timber 701.08 Composite Wood Collection	Product is composed from organic fiber - no timber used- Refer confirmation letter. Clauses not applicable to material.
701.03 Asbestos Containing Materials	Supplier provided declaration letter and test report confirming no asbestos or chromated copper arsenate
701.04 Lead or Heavy Metal Containing Materials	Test report from Eurofin provided and product is lead/ heavy metals are not detected.
701.06 Recycled Materials	Recycled Content certification from Green Label provided - 50% RCV.

Note: Regardless of applicability, supplier is requested to provide a declaration letter confirming that their products do not contain any asbestos. Letter will be included within the DGBR Site File.

Climatize Signature/ Stamp:

Date: 31/03/2020

